



GRANITE STATE ANALYTICAL SERVICES, LLC
 22 Manchester Road, Unit 2, Derry, NH 03038
 Phone (800) 699-9920 (603) 432-3044 Fax (603) 434-4837
<http://www.granitestateanalytical.com/>

DATE PRINTED: 01/04/2019

LEAD AND COPPER RESULTS

LAB ID#: 1015

COMPLIANCE PERIOD: CHEMICAL RESULTS FOR THE QUARTER 2018

SYSTEM NAME: KRSD SAU 65
 SYSTEM TOWN: New London
 SAMPLE CATEGORY: Routine Sample
 SAMPLING AGENT: Laughton, Rich-Secondwind

 SAMPLE AGENT #: 641-5767
 RECEIPT TEMP: 20.0° CELSIUS

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

EPA ID #:
 WATER SYSTEM TYPE:
 TEST UNITS: mg/L ANALYST: JLR-NH
 METHOD: Copper EPA 200.8 Lead EPA 200.8
 MCL: Copper 1.30 mg/L, Lead 0.015 mg/L
 MDL (RL): Copper 0.001 mg/L, Lead 0.001 mg/L
 DATE & TIME RECEIVED: 12/27/2018 4:02PM

SAMPLE LOCATION	DATE/TIME COLLECTED		LABORATORY SAMPLE ID#	CLIENT JOB #	LEAD *	Pass /Fail	DQ	DATE ANALYZED	COPPER *	Pass /Fail	DQ	DATE ANALYZED
SAU Lobby Bubbler	12/27/2018	12:58PM	1812-02553-001		<0.001			01/03/19				
Admin Sink	12/27/2018	1:00PM	1812-02553-002		0.0066			01/03/19				
Copier Room	12/27/2018	1:01PM	1812-02553-003		0.0078			01/03/19				
PDC Conference Room Sink	12/27/2018	1:02PM	1812-02553-004		0.0089			01/03/19				
Learning Center	12/27/2018	1:05PM	1812-02553-005		0.0031			01/03/19				
James House Kitchen	12/27/2018	1:07PM	1812-02553-006		0.0020			01/03/19				

The results presented in this report relate to the samples listed above in the condition in which they were received.
 RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.
 Laboratory Director