



GRANITE STATE ANALYTICAL SERVICES, LLC
 22 Manchester Road, Unit 2, Derry, NH 03038
 Phone (800) 699-9920 (603) 432-3044 Fax (603) 434-4837
<http://www.granitestateanalytical.com/>

DATE PRINTED: 01/04/2019

LEAD AND COPPER RESULTS

LAB ID#: 1015

COMPLIANCE PERIOD: CHEMICAL RESULTS FOR THE QUARTER 2018

SYSTEM NAME: Kearsarge Regional Middle Sch
 SYSTEM TOWN: Sutton
 SAMPLE CATEGORY: Routine Sample
 SAMPLING AGENT: Vaughn, Chris-Secondwind
 SAMPLE AGENT #: 603-641-5767
 RECEIPT TEMP: 20° CELSIUS

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

EPA ID #: 2295030
 WATER SYSTEM TYPE: Non-Transient, Non-Community
 TEST UNITS: mg/L ANALYST: CW-NH
 METHOD: Copper EPA 200.8 Lead EPA 200.8
 MCL: Copper 1.30 mg/L, Lead 0.015 mg/L
 MDL (RL): Copper 0.001 mg/L, Lead 0.001 mg/L
 DATE & TIME RECEIVED: 12/27/2018 4:03PM

SAMPLE LOCATION	DATE/TIME COLLECTED	LABORATORY SAMPLE ID#	CLIENT JOB #	LEAD *	Pass /Fail	DQ	DATE ANALYZED	COPPER *	Pass /Fail	DQ	DATE ANALYZED
Gym Left Bubblers	12/27/2018 10:02AM	1812-02548-001		<0.001			01/03/19				
Gym Left Middle Bubblers	12/27/2018 10:02AM	1812-02548-002		<0.001			01/03/19				
Gym Right Middle Bubblers	12/27/2018 10:03AM	1812-02548-003		<0.001			01/03/19				
Gym Right Bubblers	12/27/2018 10:03AM	1812-02548-004		<0.001			01/03/19				
6-2 Pod Left Bubblers	12/27/2018 10:07AM	1812-02548-005		<0.001			01/03/19				
Rm 262	12/27/2018 10:09AM	1812-02548-007		<0.001			01/03/19				
Rm 117	12/27/2018 9:44AM	1812-02548-008		<0.001			01/03/19				
6th Grade Hall Left Bubblers	12/27/2018 9:47AM	1812-02548-009		<0.001			01/03/19				
6th Grade Hall Right Bubblers	12/27/2018 9:47AM	1812-02548-010		<0.001			01/03/19				
6-1 Pod Left Bubblers	12/27/2018 9:53AM	1812-02548-011		<0.001			01/03/19				

The results presented in this report relate to the samples listed above in the condition in which they were received.
 RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.
 Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC
 22 Manchester Road, Unit 2, Derry, NH 03038
 Phone (800) 699-9920 (603) 432-3044 Fax (603) 434-4837
<http://www.granitestateanalytical.com/>

DATE PRINTED: 01/04/2019

LEAD AND COPPER RESULTS

LAB ID#: 1015

COMPLIANCE PERIOD: CHEMICAL RESULTS FOR THE QUARTER 2019

SYSTEM NAME: Kearsarge Regional Middle Sch
 SYSTEM TOWN: Sutton
 SAMPLE CATEGORY: Routine Sample
 SAMPLING AGENT: Vaughn, Chris-Secondwind

 SAMPLE AGENT #: 603-641-5767
 RECEIPT TEMP: 20° CELSIUS

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

EPA ID #: 2295030
 WATER SYSTEM TYPE: Non-Transient, Non-Community
 TEST UNITS: mg/L ANALYST: CW-NH
 METHOD: Copper EPA 200.8 Lead EPA 200.8
 MCL: Copper 1.30 mg/L, Lead 0.015 mg/L
 MDL (RL): Copper 0.001 mg/L, Lead 0.001 mg/L
 DATE & TIME RECEIVED: 12/27/2018 4:03PM

SAMPLE LOCATION	DATE/TIME COLLECTED	LABORATORY SAMPLE ID#	CLIENT JOB #	LEAD *	Pass /Fail	DQ	DATE ANALYZED	COPPER *	Pass /Fail	DQ	DATE ANALYZED
Rm 167	12/27/2018 9:55AM	1812-02548-013		<0.001			01/03/19				
Kitchen Prep	12/27/2018 9:58AM	1812-02548-014		0.0033			01/03/19				
Kitchen 2 Bay	12/27/2018 9:59AM	1812-02548-015		0.0018			01/03/19				
Gym Bottle Filler	12/27/2018 10:00AM	1812-02548-016		<0.001			01/03/19				
Rm 235 Purple	12/27/2018 10:15AM	1812-02548-017		<0.001			01/03/19				
Rm 235 Blue	12/27/2018 10:15AM	1812-02548-018		0.0011			01/03/19				
Rm 235 Orange	12/27/2018 10:15AM	1812-02548-019		0.0020			01/03/19				
Rm 235 Green	12/27/2018 10:15AM	1812-02548-020		<0.001			01/03/19				
Rm 235 Red	12/27/2018 10:15AM	1812-02548-021		<0.001			01/03/19				
7-2 Pod Left Bubblers	12/27/2018 10:18AM	1812-02548-022		<0.001			01/03/19				

The results presented in this report relate to the samples listed above in the condition in which they were received.
 RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.
 Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC
 22 Manchester Road, Unit 2, Derry, NH 03038
 Phone (800) 699-9920 (603) 432-3044 Fax (603) 434-4837
<http://www.granitestateanalytical.com/>

DATE PRINTED: 01/04/2019

LEAD AND COPPER RESULTS

LAB ID#: 1015

COMPLIANCE PERIOD: CHEMICAL RESULTS FOR THE QUARTER 2019

SYSTEM NAME: Kearsarge Regional Middle Sch
 SYSTEM TOWN: Sutton
 SAMPLE CATEGORY: Routine Sample
 SAMPLING AGENT: Vaughn, Chris-Secondwind
 SAMPLE AGENT #: 603-641-5767
 RECEIPT TEMP: 20° CELSIUS

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

EPA ID #: 2295030
 WATER SYSTEM TYPE: Non-Transient, Non-Community
 TEST UNITS: mg/L ANALYST: CW-NH
 METHOD: Copper EPA 200.8 Lead EPA 200.8
 MCL: Copper 1.30 mg/L, Lead 0.015 mg/L
 MDL (RL): Copper 0.001 mg/L, Lead 0.001 mg/L
 DATE & TIME RECEIVED: 12/27/2018 4:03PM

SAMPLE LOCATION	DATE/TIME COLLECTED	LABORATORY SAMPLE ID#	CLIENT JOB #	LEAD *	Pass /Fail	DQ	DATE ANALYZED	COPPER *	Pass /Fail	DQ	DATE ANALYZED
7-2 Pod Right Bubblers	12/27/2018 10:18AM	1812-02548-023		<0.001			01/03/19				
Rm 231	12/27/2018 10:19AM	1812-02548-024		<0.001			01/03/19				
Rm 148	12/27/2018 9:34AM	1812-02548-025		<0.001			01/03/19				
Rm 143	12/27/2018 9:35AM	1812-02548-026		0.0011			01/03/19				
Rm 114	12/27/2018 9:36AM	1812-02548-027		<0.001			01/03/19				
8-1 Pod Left Bubblers	12/27/2018 9:37AM	1812-02548-028		<0.001			01/03/19				
8-1 Pod Right Bubblers	12/27/2018 9:37AM	1812-02548-029		<0.001			01/03/19				
Rm 129	12/27/2018 9:40AM	1812-02548-030		<0.001			01/03/19				
8-1 Pod Staff Rm	12/27/2018 9:41AM	1812-02548-031		<0.001			01/03/19				
8-2 Pod Left Bubblers	12/27/2018 9:43AM	1812-02548-032		<0.001			01/03/19				

The results presented in this report relate to the samples listed above in the condition in which they were received.
 RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.
 Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC
 22 Manchester Road, Unit 2, Derry, NH 03038
 Phone (800) 699-9920 (603) 432-3044 Fax (603) 434-4837
<http://www.granitestateanalytical.com/>

DATE PRINTED: 01/04/2019

LEAD AND COPPER RESULTS

LAB ID#: 1015

COMPLIANCE PERIOD: CHEMICAL RESULTS FOR THE QUARTER 2019

SYSTEM NAME: Kearsarge Regional Middle Sch
 SYSTEM TOWN: Sutton
 SAMPLE CATEGORY: Routine Sample
 SAMPLING AGENT: Vaughn, Chris-Secondwind
 SAMPLE AGENT #: 603-641-5767
 RECEIPT TEMP: 20° CELSIUS

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	⚠
Fails State Guideline	✕
Attention	⚠

EPA ID #: 2295030
 WATER SYSTEM TYPE: Non-Transient, Non-Community
 TEST UNITS: mg/L ANALYST: CW-NH
 METHOD: Copper EPA 200.8 Lead EPA 200.8
 MCL: Copper 1.30 mg/L, Lead 0.015 mg/L
 MDL (RL): Copper 0.001 mg/L, Lead 0.001 mg/L
 DATE & TIME RECEIVED: 12/27/2018 4:03PM

SAMPLE LOCATION	DATE/TIME COLLECTED		LABORATORY SAMPLE ID#	CLIENT JOB #	LEAD *	Pass /Fail	DQ	DATE ANALYZED	COPPER *	Pass /Fail	DQ	DATE ANALYZED
					<0.001	✓		01/03/19	<0.001	✓		01/03/19
8-2 Pod Right Bubbler	12/27/2018	9:43AM	1812-02548-033		<0.001	✓		01/03/19	<0.001	✓		01/03/19
7-1 Pod Left Bubbler	12/27/2018	10:21AM	1812-02548-034		<0.001	✓		01/03/19	<0.001	✓		01/03/19
7-1 Pod Right Bubbler	12/27/2018	10:22AM	1812-02548-035		<0.001	✓		01/03/19	<0.001	✓		01/03/19
Rm 214	12/27/2018	10:33AM	1812-02548-036		<0.001	✓		01/03/19	<0.001	✓		01/03/19
Guidance	12/27/2018	10:30AM	1812-02548-037		0.0023	✓		01/03/19				

The results presented in this report relate to the samples listed above in the condition in which they were received.
 RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

* NELAP Accredited Analysis



Donald A. D'Anjou
 Donald A. D'Anjou, Ph. D.
 Laboratory Director