



GRANITE STATE ANALYTICAL SERVICES, LLC
 22 Manchester Road, Unit 2, Derry, NH 03038
 Phone (800) 699-9920 (603) 432-3044 Fax (603) 434-4837
<http://www.granitestateanalytical.com/>

DATE PRINTED: 01/04/2019

LEAD AND COPPER RESULTS

LAB ID#: 1015

COMPLIANCE PERIOD: CHEMICAL RESULTS FOR THE QUARTER 2018

SYSTEM NAME: Simonds Elementary School
 SYSTEM TOWN: Warner
 SAMPLE CATEGORY: Routine Sample
 SAMPLING AGENT: Vaughn, Chris-Secondwind

 SAMPLE AGENT #: 603-641-5767
 RECEIPT TEMP: 20° CELSIUS

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	⚠
Fails State Guideline	✗
Attention	⚠

EPA ID #:
 WATER SYSTEM TYPE:
 TEST UNITS: mg/L ANALYST: CW-NH
 METHOD: Copper EPA 200.8 Lead EPA 200.8
 MCL: Copper 1.30 mg/L, Lead 0.015 mg/L
 MDL (RL): Copper 0.001 mg/L, Lead 0.001 mg/L
 DATE & TIME RECEIVED: 12/27/2018 4:04PM

SAMPLE LOCATION	DATE/TIME COLLECTED	LABORATORY SAMPLE ID#	CLIENT JOB #	LEAD *	Pass /Fail	DQ	DATE ANALYZED	COPPER *	Pass /Fail	DQ	DATE ANALYZED
Meeting Room	12/27/2018 8:02AM	1812-02551-001		0.0051	✓		01/03/19				
Staff Break Room	12/27/2018 8:03AM	1812-02551-002		0.0015	✓		01/03/19				
Main Hall Bubbler	12/27/2018 8:04AM	1812-02551-003		<0.001	✓		01/03/19				
Main Hall Bottle Filler	12/27/2018 8:05AM	1812-02551-004		<0.001	✓		01/03/19				
Multipurpose Rm Bubbler	12/27/2018 8:07AM	1812-02551-005		<0.001	✓		01/03/19				
Multipurpose Rm Bottle Filler	12/27/2018 8:08AM	1812-02551-006		<0.001	✓		01/03/19				
Kindergarten Rm 22	12/27/2018 8:10AM	1812-02551-007		<0.001	✓		01/03/19				
Kitchen 3 Bay Left Faucet	12/27/2018 8:13AM	1812-02551-008		0.0013	✓		01/03/19				
Kitchen 3 Bay Right Faucet	12/27/2018 8:13AM	1812-02551-009		0.0034	✓		01/03/19				

The results presented in this report relate to the samples listed above in the condition in which they were received.
 RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.
Laboratory Director