



**GRANITE STATE ANALYTICAL SERVICES, LLC**  
 22 Manchester Road, Unit 2, Derry, NH 03038  
 Phone (800) 699-9920 (603) 432-3044 Fax (603) 434-4837  
<http://www.granitestateanalytical.com/>

DATE PRINTED: 01/04/2019

**LEAD AND COPPER RESULTS**

LAB ID#: 1015

COMPLIANCE PERIOD: CHEMICAL RESULTS FOR THE QUARTER 2018

SYSTEM NAME: Sutton Central Sch  
 SYSTEM TOWN: Sutton  
 SAMPLE CATEGORY: Routine Sample  
 SAMPLING AGENT: Vaughn, Chris-Secondwind  
  
 SAMPLE AGENT #: 603-641-5767  
 RECEIPT TEMP: 20° CELSIUS

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

EPA ID #: 2295020  
 WATER SYSTEM TYPE: Non-Transient, Non-Community  
 TEST UNITS: mg/L ANALYST: CW-NH  
 METHOD: Copper EPA 200.8 Lead EPA 200.8  
 MCL: Copper 1.30 mg/L, Lead 0.015 mg/L  
 MDL (RL): Copper 0.001 mg/L, Lead 0.001 mg/L  
 DATE & TIME RECEIVED: 12/27/2018 4:04PM

SAMPLE LOCATION	DATE/TIME COLLECTED	LABORATORY SAMPLE ID#	CLIENT JOB #	LEAD *	Pass /Fail	DQ	DATE ANALYZED	COPPER *	Pass /Fail	DQ	DATE ANALYZED
Outside Nurse Bubblers	12/27/2018 10:45AM	1812-02549-001		<0.001			01/03/19				
Outside Nurse Bottle Filler	12/27/2018 10:45AM	1812-02549-002		<0.001			01/03/19				
Nurse Sink	12/27/2018 10:48AM	1812-02549-003		0.0012			01/03/19				
Staff Break Room	12/27/2018 10:50AM	1812-02549-004		<0.001			01/03/19				
Hallway Bubblers	12/27/2018 10:51AM	1812-02549-005		0.0013			01/03/19				
Classroom 1 (1)	12/27/2018 10:52AM	1812-02549-006		0.0031			01/03/19				
Classroom 1 (2)	12/27/2018 10:52AM	1812-02549-007		0.0022			01/03/19				
Kindergarten	12/27/2018 10:54AM	1812-02549-008		<0.001			01/03/19				
MPR Bubblers	12/27/2018 10:55AM	1812-02549-009		<0.001			01/03/19				
Kitchen Prep Sink	12/27/2018 10:57AM	1812-02549-010		<0.001			01/03/19				

The results presented in this report relate to the samples listed above in the condition in which they were received.  
 RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

\* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.  
 Laboratory Director